



INSPECTION AND TEST REPORT



www.kingsenergy.com
1-866-660-KING

Owner:	CANADIAN NATURAL RES	AFE:		Date:	06/26/2012	Job:	44434
Instructions:	☐ Rental ☐ Quote ☒ Pretest ☒ Repair ☐ Test Only ☐ New ☐ Reset ☐ B.E.R ☐ VR Update						
L.S.D.:	09-29-074-10W6	Loc:	FUEL GAS	Plant/Area:	KNOPCIK	Unit/Vessel:	A3113862

Valve Data:	-	Seal:	Intact	Style:	Threaded	Inlet:	MNPT	Outlet:	FNPT
		Seal ID:	TBG	Bonnet:	Closed	Inlet Size:	0.75 inches	Outlet Size:	1.00 inches
Make:	Farris	NamePlate:	Original	Cap:	Closed	Inlet Rating:	Threaded	Outlet Rating:	Threaded
CRN:	0G2367.5C	Service:	Sweet	Orifice:		Capacity:	516 SCFM	Cold Diff Set	150 psig
Asset No:	75001	Product:	Gas	Orifice Area:		Code Stmp:	NB/UV	Set Press:	150 psig
Data Plate:	1850	Serial No:	CE-24253-R1	Replacing:					

Pilot Data:		Model:		Serial No:	
--------------------	--	---------------	--	-------------------	--

Pretest Data:	Test1:	Test2:	Test3:	Units:	Notes1:	Customer Request	Pretest By:	Justin Moyer
Pressures:	154	0	0	psig	Notes2:	Passed		

Disassembly:	-	Height:	0.536 IN	Upper BDR:		Lower DBR:		Dis By:	Tyson Horne
---------------------	---	----------------	----------	-------------------	--	-------------------	--	----------------	-------------

Inspection:	-	Replaced:	N	Converted:	N	Inspected By:	Fergie
Seat Matl:		Bonnet Matl:		Sizing Basis:	Blocked Flow	Inlet Condition:	Good
Body Matl:	Carbon Steel	Bellows Matl:		Spring No:		Outlet Cond:	Good

Part No \ Desc:	Bin Loc:	Condition 1	Condition 2	Recommendation	Work Done	CD Actual
DISC						0.053
NOZZLE						0.295
301902-010 : GASKET		Worn	Req's Replacing		Replaced	

Assembly:	-	Converted From:		Converted To:		Assembled By:	Tyson Horne
------------------	---	------------------------	--	----------------------	--	----------------------	-------------

Final Test:	-	Set Press:	150 psig	Gauge 1:	45692	Vacuum Set:		-	-
	-	Back Press:		Gauge 2:	45693	Leakage Vac:		Test Date:	06/26/2012
Media:	Air	Temp:	60 °F	BLD %:		Vacuum Act:		Tested By:	Justin Moyer
Method:	Bench	Corr Factor:	0	Meas Lift:		-	-	Witness:	
Simmer:		Cold Diff Set:	150 psig	Leakage:	0 BPM	Set Press Def:	POP	-	-
Re-Seat:		Act Test Press:	150 psig	-	-	-	-	-	-

Final Insp:	Tag:	Painted:	Pallet:	Sealed:	End Protect:	Flex Gasket:	Inspector:	Justin Moyer
	Yes	Yes	No	Yes	Yes	No	Sign Off:	Stephen Loder
Reset Comments:								
Inspection Comments:								
Final Test Comments:								
Sign Off Comments:								