



PSV DATA

MFG: KNUCKLE
 MODEL: 6030HGN01-EN0010
 SERIAL: N/S
 SET PRES: 69 kPa
 CAPACITY: 1083 lbs/hr
 SERVICED BY: N/S
 SERVICE DATE: N/S
 SIZE: 1in x 1.5in
 CODE STAMP: N/S
 BLOCK VALVE: NO
 CRN: N/S
 LOCATION: TOP SHELL
 TAG: N/S

SIZE
 REBOILER: 40in x 140in
 ACCUMULATOR: 3ft x 64in

Equip. No. _____ Prov. Reg. No. **RAE 2966** C.R.N. **NON CODE** Serial No. _____ Yr. Inst. _____
 Code/Div. **NON CODE** Size: **36in x 132in** Manufacturer: **WELLS HALL FAB.** Yr. Blt. **2001**
 C. Stamp: **NO** Service: **SWEET** PWHT: **NIL** Radiography: **NIL** Insulated: **YES**

Design & Materials Data

HEAD:
 Top Mat'l. _____ Top Nom. _____ Top C.A. _____
 Btm. Mat'l. _____ Btm. Nom. _____ Btm. C.A. _____
CHANNEL:
 Material: _____ Nominal: _____ C.A. _____
BOOT
 Head Mat'l. _____ Head Nom. _____ Head C.A. _____
 Shell Mat'l. _____ Shell Nom. _____ Shell C.A. _____
SHELL
 Material: _____ Nominal: _____ C.A. _____
 MAWP Shell Side: **ATMOS.** @ Temp. _____
 MAWP Tube Side: _____ @ Temp. _____

CLIENT	CANADIAN NATURAL RESOURCES
FACILITY	LADYFERN DEHYDRATION #6 LSD b-17-1/94-H-01
ITEM	GLYCOL REBOILER/ ACCUMULATOR
BY: LR	DATE: 12/2005 DWG.# 3-3

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: GLYCOL REBOILER ACCUMULATOR
CRN#:
PROV REG: RAE 2966
TESTED ON STREAM

FACILITY: LADYFERN GAS PLANT
SERVICE: SWEET
LOCATION: b-17-I/94-H-01
RTD JOB #: 105.00390
REFER TO DRAWING: 3-3

Test Point	THICKNESS DATA				Flag	Crit	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Flag Date
305	Description: TOP SHELL											
	2005	12	2010	6								
Min. Thick.	10.4		10.4		0				0	0		L
Average:	10.5		10.5						0	0		L
Analysis:												
310	Description: BOTTOM SHELL											
	2005	12	2010	6								
Min. Thick.	10.2		10.2		0				0	0		L
Average:	10.4		10.4						0	0		L
Analysis:												
315	Description: LOWER SHELL ON STACK											
	2005	12	2010	6								
Min. Thick.	6.4		6.4		0				0	0		L
Average:	6.5		6.5						0	0		L
Analysis:												