



PSV DATA

MFG: TAYLOR
 MODEL: T-8200-1
 SERIAL: 20175-860
 SET PRES: 9929 kPa
 CAPACITY: 3149 scfm
 SERVICED BY: IPV
 SERVICE DATE: 05/2005
 SIZE: 1"x1"
 CODE STAMP: UV/NB
 BLOCK VALVE: NO
 CRN: OG1316.2C
 LOCATION: UPPER SHELL
 TAG: 2039

Equip. No. _____ Prov. Reg. No. **2808798** C.R.N. **K-2542.2** Serial No. **109.66.92** Yr. Inst. _____
 Code/Div. **ASME VIII, Div 1** Size: **16in x 103in** Manufacturer: **MAR-QUINN** Yr. Blt. **1992**
 C. Stamp: **U** Service: **SWEET** PWHT: **NIL** Radiography: **RT2** Insulated: **NO**

Design & Materials Data

HEAD:
 Top Mat'l. **SA 516 70** Top Nom. **20.7mm** Top C.A. _____
 Btm. Mat'l. _____ Btm. Nom. _____ Btm. C.A. _____
CHANNEL:
 Material: _____ Nominal: _____ C.A. _____
BOOT
 Head Mat'l. _____ Head Nom. _____ Head C.A. _____
 Shell Mat'l. _____ Shell Nom. _____ Shell C.A. _____
SHELL
 Material: **SA 106 B** Nominal: **21.4mm** C.A. _____
 MAWP Shell Side: **9929 kPa** @ Temp. **38°C**
 MAWP Tube Side: _____ @ Temp. _____

CLIENT	CANADIAN NATURAL RESOURCES		
FACILITY	KNOPCIK GAS GATHERING LSD 14-11-74-11 W6M		
ITEM	SEPARATOR PIPING		
BY: NR	DATE: 2010/03	DWG.# 23	

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: SEPARATOR PIPING
CRN#:
PROV REG:
TESTED ON STREAM

FACILITY: KNOPCIK GAS GATHERING
SERVICE: SWEET
LOCATION: 14-11-74-11 W6M
RTD JOB #: 05.004259
REFER TO DRAWING: 23

Test Point	THICKNESS DATA		Flag	Crit	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Flag Date
105	Description: 3" 90° ELBOW 2010 3									
	Min. Thick.	6.4	4.81		.7	5.5				L
	Average:	6.8					0	0		L
	Analysis:									
140	Description: 3" 90° ELBOW 2010 3									
	Min. Thick.	5.4	4.81		.7	5.5				L
	Average:	5.6					0	0		L
	Analysis:									
145	Description: 3" 90° ELBOW 2010 3									
	Min. Thick.	5.7	4.81		.7	5.5				L
	Average:	5.8					0	0		L
	Analysis:									
150	Description: 3" 90° ELBOW 2010 3									
	Min. Thick.	5.3	4.81		.7	5.5				L
	Average:	5.4					0	0		L
	Analysis:									