



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156960-MD-09**
 Inspect Date: 10/16/2012
 Page: 1 of 15
 Insp. Co. Job #: 156960

Criticality Designation:



Yellow

Insp. Comp: Matrix_Inspection District: Grande Prairie - North Field: Chincaga
 Location: 01-24-096-05W6 Unit / Skid #: N/A LSD: 01-24-096-05W6
 Jurisdiction #: A0146908 Equip Tag #: V-301A Serial #: 79-087-05A
 CRN #: D 3193.2 Nat'l Bd #: N/A Year Built: 1980
 Manufacturer: KML Manufacturing Equipment Description: Other: Gas Dehydrator
 Status: Out of Service - 888 - Equip. Type: Vessel: Tower Service: Sweet
 MAWP Shell: 8619 kPa @ 343 °C Volume: N/A Code Stamp: Y N
 MAWP Tube: @ Height/Length: 8992 mm Insulated: Y N
 MDMT: -20 °F RT: RT-1 Size/Diameter.: 1677 mm I.D. PWHT: Y N
 Support: Skirt Vessel on Original CNRL Inventory List: Y N Manway: Y N
 C.A.: 1.58 mm Coated: N/A Clad: N/A J.E.: 1.00 Remote Access: -

Component	Material	Nominal Thk	Diameter	OD/ID	Tube Side	Shell Side
1 Main - Shell	SA-516-70	88.500 mm	1677.000 mm	ID	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2 Top - Head	SA-516-70	69.270 mm	1677.000 mm	ID	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3 Bottom - Head	SA-516-70	69.270 mm	1677.000 mm	ID	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4 -					<input type="checkbox"/>	<input type="checkbox"/>
5 -					<input type="checkbox"/>	<input type="checkbox"/>

Static Data: Confirmed Changed (See Comments)

Comments:

Static data confirmed
 Maximum Design Pressure: 9481 kPa

PSV Static Data

PSV -1 Tag #: N/A Serial #: N/A CRN: N/A
 Model #: N/A Capacity: N/A Set Pressure: N/A
 Manufacturer: N/A Service Company: N/A
 Inlet Size & Type: - Last Service Date: N/A
 Outlet Size & Type: - Block Valve: - -
 Carseal Intact: N/A Code Stamp: _____
 Shell Side / Tube Side: _____ Out for Service During Insp.: _____ Location of PSV: _____

PSV -2 Tag #: _____ Serial #: _____ CRN: _____
 Model #: _____ Capacity: _____ Set Pressure: _____
 Manufacturer: _____ Service Company: _____
 Inlet Size & Type: - Last Service Date: _____
 Outlet Size & Type: - Block Valve: - -
 Carseal Intact: _____ Code Stamp: _____
 Shell Side / Tube Side: _____ Out for Service During Insp.: _____ Location of PSV: _____

PSV Comments

Not applicable



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156960-MD-09**
 Inspect Date: 10/16/2012
 Page: 2 of 15
 Insp. Co. Job #: 156960

Insp. Company: Matrix Inspection LSD: 01-24-096-05W6 Jurisdiction #: A0146908

External Inspection Results – VE External Inspection Performed

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Nameplate	<input type="checkbox"/>	Accept	Legible and broken rivet	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Foundation and Supports	<input type="checkbox"/>	Accept	Welded skirt anchored to skid	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Anchor Bolts	<input type="checkbox"/>	Accept	Secure with minor surface corrosion	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Grounding	<input type="checkbox"/>	Accept	Grounded directly to South side of skirt	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation Condition	<input type="checkbox"/>	Reject	Piping cladding damaged and moss growth	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
PSV	<input checked="" type="checkbox"/>		Not applicable	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Shell Heads & Nozzles	<input type="checkbox"/>	Accept	Minor surface corrosion through out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Metal Surfaces (Paint)	<input type="checkbox"/>	Accept	Chipped and flaking exposing base metal	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Aux Equipment	<input checked="" type="checkbox"/>		Not applicable	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cathodic Protection	<input checked="" type="checkbox"/>		No external anode	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alignment	<input type="checkbox"/>	Accept	Vertical and upright	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flange Connections	<input type="checkbox"/>	Accept	Adequate thread engagement and hardware	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Pressure Gauge	<input checked="" type="checkbox"/>		No pressure gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature Gauge	<input type="checkbox"/>	Reject	2 temp gauges not within range	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sight Glass	<input checked="" type="checkbox"/>		No sight glass	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ladder / Platform	<input type="checkbox"/>	Accept	2 platforms are secure with cages for ladder	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Leaks	<input type="checkbox"/>	No	No evidence of leaks	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Piping from Vessel	<input type="checkbox"/>	Accept	Riser saddle and lug supports for associated piping			
Previous UT Survey	<input type="checkbox"/>	Yes	Locations marked, no history provided	UT Company: N/A		

External Visual Observations

At the time of inspection the dehydrator was not in service and the vessel is tagged out of service
 There is a broken rivet on the nameplate
 The coating is flaking and chipped throughout exposing the base metal to very minor surface corrosion with no evidence of pitting.

There are two 24" manways on the vessel. The East side manway, hardware and davit arm are in acceptable condition
 The top head davit arm and pin have been removed

The 0-300 C temperature gauges are not within design temp range and the 0-500 C gauge needle is at the 500 C mark

All platforms and ladders are secure with well supported cages on the ladders
 The top 8" inlet piping cladding is damaged and punctured with moss growth at the cladding interface that may result in MIC
 The outlet/inlet piping has a small section of cladding/insulation removed, the insulation is exposed, discolored and deteriorating which may result in CUI to the piping system
 The top platform support beam is bent on the West side
 There is mechanical damage noted thru out the surfaces on the shells, (it appears as a tooling marks from erection)
 There is also mechanical damage on the top head below the paint

A UT corrosion survey was performed at the time of inspection with no significant wall losses recorded.

Recommendations:

Remove/ replace insulation on piping
 Replace broken rivet
 Replace temperature gauges as necessary
 Replace cladding and remove moss and treat area
 Clean and touch up the coating to aid in the protection against corrosion

If this vessel is to be moved and/or placed into service the lifting lugs and top nozzle should be MT examined as well as ABSA document AB-10 completed



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156960-MD-09**
 Inspect Date: 10/16/2012
 Page: 3 of 15
 Insp. Co. Job #: 156960

Insp. Company: Matrix_Inspection LSD: 01-24-096-05W6 Jurisdiction #: A0146908

Internal Inspection Results – VI N/A (Not Applicable)

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Shell	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heads	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Manway	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Gasket Surfaces	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Welds	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Refractory	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heating Coils	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Demister Pad	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vane Pack	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Baffles	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Trays	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Internal Coating	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tubesheet	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tube Bundle	<input checked="" type="checkbox"/>		No Internal Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Internal Visual Observations

No Internal Inspection Carried Out

Recommendations:

No Internal Inspection Carried Out



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156960-MD-09**
 Inspect Date: 10/16/2012
 Page: 4 of 15
 Insp. Co. Job #: 156960

Insp. Company: Matrix_Inspection LSD: 01-24-096-05W6 Jurisdiction #: A0146908

Firetube Static Data N/A (Not Applicable)

Diameter: Not Applicable Nom Thickness: Not Applicable Bend: Not Applicable
 Length: Not Applicable Firetube Description: Not Applicable

Firetube NDE Performed: UT Report#: Not Applicable ET Report#: Not Applicable
 MT Report#: Not Applicable RT Report#: Not Applicable
 PT Report#: Not Applicable Other Report#: Not Applicable

Firetube Inspection Results

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Burner	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Stack	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flange (Throat)	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tube Sheet	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hot Side	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Miter	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Return Bend	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Supports	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Butt Welds	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fillet Welds	<input checked="" type="checkbox"/>		No Firetube Inspection Carried Out	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Firetube Visual Observations

No Firetube Inspection Carried Out

Recommendations:

No Firetube Inspection Carried Out



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: 156960-MD-09
Inspect Date: 10/16/2012
Page: 5 of 15
Insp. Co. Job #: 156960

Insp. Company: Matrix_Inspection LSD: 01-24-096-05W6 Jurisdiction #: A0146908

Vessel NDE and Final Summary:

NDE Performed: UT Report#: _____ ET Report#: _____
MT Report#: _____ RT Report#: _____
PT Report#: _____ Other Report#: _____

Maxi-Trak Observations Summary (Summarize inspection results Max 255 Characters):

Coating deteriorated exposing base metal to surface corrosion
Moss growth and damaged insulation on 8" inlet piping
Temp gauges not within range and 500C gauge needle is at 500C
Broken nameplate rivet

Maxi-Trak Recommendations Summary (Summarize Recommendations Max 255 Characters):

Clean and touch up the coating to aid in the protection against corrosion
Replace temp gauges as required
Remove moss and treat area, replace insulation
Replace nameplate rivet

Actions Corrected at Time of Inspection: (If actions were corrected at the time of Inspection – note the corrected actions here.)

No actions were corrected at the time of inspection

Additional Visual Observations

No additional visual observations

Any other safety concerns or observations from associated equipment: (for example associated piping, buildings, pumps etc...)

No safety concerns noted at the time of inspection



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: 156960-MD-09
Inspect Date: 10/16/2012
Page: 6 of 15
Insp. Co. Job #: 156960

Insp. Company: Matrix_Inspection LSD: 01-24-096-05W6 Jurisdiction #: A0146908

Thickness and Remaining Life Evaluation “ Must be Completed”

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF LOW WALL THICKNESS AREAS

Step 1: Was any thickness measurement location found to be less than (Nominal WT – Corrosion Allowance)?: **No**

If YES, proceed to Step 2; if NO, proceed to “Crack Evaluation” and “CNRL Criticality Designation”.

Step 2: Which component(s) were found below (Nominal WT – Corrosion Allowance)?

Components found below Nom - CA:

Components
Top - Head
- Shell
Bottom - Head
Bottom - Drain Nozzle
N/A - N/A

Perform Steps 3 – 8 for each component with actual thickness less than (Nominal WT – Corrosion Allowance).

Step 3: Describe Location and Extent of Corrosion:

Components	Location and Extent of Corrosion
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection

Notes:

Circumferential stress values used for nozzle

Step 4:

- For shells and nozzles, calculate minimum required thickness (T-min) as per ASME Section VIII UG-27.
- For heads, calculate minimum required thickness (T-min) as per ASME Section VIII UG-32.

Components	T-Min
Top - Head	2.374
- Shell	1.162
Bottom - Head	2.374
Bottom - Drain Nozzle	0.304
N/A - N/A	N/A



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: **156960-MD-09**
Inspect Date: 10/16/2012
Page: 7 of 15
Insp. Co. Job #: 156960

Insp. Company: Matrix_Inspection LSD: 01-24-096-05W6 Jurisdiction #: A0146908

Thickness and Remaining Life Evaluation (Continued)

Step 5: Is any measured thickness less than calculated minimum required thickness (T-min)? **N/A**

*If YES, complete Step 6
If NO, proceed to Step 7..*

Step 6: Is nature and extent of pitting acceptable as per API 510? **N/A**

Step 7: Calculate Remaining Life as per API 510. How? (Find last reading; use nominal thickness if nothing available). Short Term Corrosion Rates and Long Term Corrosion Rates.

Components	Remaining Life (Yrs)
Top - Head	99
- Shell	99
Bottom - Head	99
Bottom - Drain Nozzle	99
N/A - N/A	N/A

Step 8: Contact CNRL Integrity Coordinator to discuss above results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation:
Not Applicable for this Inspection

Crack Evaluation by Magnetic Particle or Alternative Inspection “Must be Completed”

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF CRACK-LIKE INDICATIONS

Were any indications found to suggest the vessel contained cracks? **N/A**

If NO, proceed to “CNRL Criticality Designation”.

If YES, Contact CNRL Integrity Coordinator to discuss results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation:
Not Applicable for this Inspection



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156960-MD-09**
 Inspect Date: 10/16/2012
 Page: 8 of 15
 Insp. Co. Job #: 156960

Insp. Company: Matrix_Inspection LSD: 01-24-096-05W6 Jurisdiction #: A0146908

CNRL Criticality Evaluation – “MUST BE COMPLETED”

The CNRL In-Service Pressure Vessel Inspector MUST answer all the following questions

1. Is the vessel fit-for-service? : **Yes**
2. Was the measured thickness less than the calculated minimum required thickness (T-min) for any component?: **No**
3. Were MT indications found?: **N/A**
4. Was the remaining life less than 6 years for sour service vessels or less than 10 years for sweet service vessels?: **No**
5. Were NCR's or Action Items generated as a result of the inspection? : **Yes**
6. Were UT readings below (Nominal WT – Corrosion Allowance) found? : **No**

Information on CNRL Owner User Program - Criticality Designation and Required Review

RED – Vessel Inspection Results are deemed RED if one of the following occurred:

- The measured thickness was less than the calculated minimum required thickness (T-min) for any component.
- MT indications were found.
- The remaining life was calculated to be less than 6 years for sour-service vessels or less than 10 years for sweet-service vessels.

RED inspection reports must be signed off by the CNRL Chief Inspector.

YELLOW – Vessel Inspection Results are deemed YELLOW if one or more of the following occurred:

- The vessel was declared NOT fit-for-service by the 3rd Party In-Service PV Inspector.
- NCR's or Action Items were generated as a result of the inspection.
- UT readings below (Nominal WT – Corrosion Allowance) were found.

YELLOW inspection reports must be signed off by the CNRL Pressure Equipment Integrity Coordinator.

GREEN – Vessel Inspection Results are deemed GREEN if all of the following are true:

- The vessel was declared fit-for-service by the 3rd Party In-Service PV Inspector.
- UT readings below (Nominal WT – Corrosion Allowance) were NOT found.
- MT indications were NOT found.
- NCR's or Action Items were NOT generated as a result of the VE inspection.

GREEN inspection reports must be signed off by the 3rd Party In-Service Pressure Vessel Inspector.

Criticality Designation



Yellow

Vehicle #: 380 Kms: _____
 Time In: 00:00 Time Out: 00:00 Hrs _____
 Time In: 00:00 Time Out: 00:00 Hrs _____
 Personnel: SJ
 Billing Info: AFE :

Inspector (Name): Matthew B Dickinson PESL: 601
 Inspector (Signature): _____
Inspector Signature
06/30/2010 08:43:20 am
 CNRL Coordinator (Name): _____
 CNRL Coordinator (Signature): _____
Coordinator Signature
09/30/2010 08:44:03 am
 CNRL Chief Inspector (Signature): _____
 (I am in full agreement with report contents)
Chief Inspector Signature
05/30/2010 08:40:29 am
 (I am in full agreement with report contents)

Equipment Photographs:



01 nameplate



02 broken rivet



03 overview



04 flash corrosion



05 not within range



05 paint deterioration



06 needle @ 500



07 mechanical damage



08 damaged insulation



09 exposed insulation



10 damaged cladding



11 moss growth



12 mechanical damage on support