

**Canadian Natural Resources Limited
GENERAL PRESSURE VESSEL INFORMATION**

Job 10.112837

District: Fort St. John North	Skid No.
Facility: Chowade Compressor Station	Location (LSD): c-29-L/94-B-09
Vessel Name Equipment Number: Flare Knock Out Drum	
Orientation: Horizontal	
Status: In Service	Regulatory Inspection

PRESSURE VESSEL NAMEPLATE DATA

"A" or "G" or "S" (Sask.) or BC Registration Number. A0459148		CRN Number: L 6182.21	
Vessel serial number: 004013-50		Size: 96 in x 120 in	
Shell thickness: 9.5 mm		Shell material: SA 516 70N	
Head thickness: 7.9 mm		Head material: SA 516 70N	
Tube wall thickness:		Tube material:	
Tube diameter:		Tube length:	
Channel thickness:		Channel material:	
Design pressure	Shell: 50 PSI	Operating pressure	Shell:
	Tubes:		Tubes:
Design Temp.	Shell: 100 F	Operating temperature	Shell:
	Tubes:		Tubes:
X-ray: Nil		Heat treatment: No	
Code parameters: ASME VIII, Div 1		Coated: Yes	
Manufacturer: Nusco		Year built: 2000	
Corrosion allowance: Nil		Manway: Yes	

PRESSURE SAFETY VALVE NAMEPLATE DATA

PSV Tag #	Manufacture / Model / Serial	Set Pressure (PSI / kPa)	Capacity (scfm)	Size	Block Valve	Location	Service by Date

SERVICE CONDITIONS-INDICATE ALL THAT APPLY

Sweet	Sour X	Oil	Gas	Water X
Amine	LPG	Condensate X	Air	Glycol X

Other (Describe):

Inspection Interval _____ **PSV Service Interval** _____

(Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program)

Reports reviewed and accepted by:

Mechanical Integrity Coordinator _____ **Date** _____

Fill out all forms as completely as possible. All information is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items	G	F	P	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.	X				Tar over foam insulation in good overall condition – small isolated tares
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)			X		Paint in poor condition - Under belly has paint loss and surface corrosion to 100% - pitting to 0.020 inch
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaks observed
Saddle/skirt Assess condition of paint, fire protection, and concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				Saddle in good overall condition: bolted directly to skid frame – no buckling or dents – no corrosion or leaks at attachment welds – skid sits on wood blocks – ground wire attached to pilings
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	X				Vessel is securely welded to skid frame – no sign of deformation
Concrete foundation Check for cracks, spalling, etc.				X	None
Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards.				X	None
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?		X			Nozzle paint in poor condition – drain nozzle paint loss and surface corrosion to 100%– all stud threads fully engaged – no leaks – no damage or deflection – nozzles are not gusseted
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.				X	No gauges
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Piping is well supported – all clamps in place – no evidence of structural overload – no deflection – paint in good condition – no corrosion
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				Valves properly supported – no sign of leaking
PSV Ensure PSV is set at pressure at or below that of vessel.				X	No PSV
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)				X	Unable to Perform UT inspection at this time due to Heavy External Corrosion.
Other					
<p>Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented) Recommendations: 1. Vessel needs to be cleaned up and Painted. 2. Schedule for Internal Inspection. Summary: This vessel is in fair condition, visual external inspection carried out.</p> <p>Vessel is fit for service.</p>					

Inspected By: Andrew Neis / D. Wiedman


Date: March 1, 2013



LSD



Overview



Data Plate



Under belly overview – Paint loss and surface corrosion to 100%