



ITEM	QTY.	SIZE	DESCRIPTION
BE-100	1	-	BURNER ELEMENT FLAME ROD PART OF PROFIRE 2100 BMS
BMS	1	-	PROFIRE 2100 BURNER MANAGEMENT SYSTEM C/W HIGH TEMPERATURE PERMISSIVE
BV-100	1	2"	WKM 150 FLG FLOAT FP BV NACE
BV-101/106	2	1"	NEO 2500 SERIES 316SS BALL VALVE, CSA LISTED, CGA 3.16 APPROVED
BV-102/103/104/105	4	¼"	NEO 2500 SERIES STAINLESS BALL VALVE
FA-100	1	2"	150 ANSI INLINE FLAME ARRESTOR
IGN-100	1	-	IGNITION MODULE PART OF PROFIRE 2100 BMS
IP-100	1	-	FAIRCHILD ELECTRO-PNEUMATIC TRANSDUCER
PCV-100	1	1"NPT	FISHER REGULATOR 627, ½" OR. 5-20 PSI, SETPOINT 16 PSIG
PCV-101/102	2	¼"NPT	FISHER 67CFR 362SC REGULATOR 0-30PSI ¼ NPT VENTING BONNET
PI-100	1	2 ½"	0 – 200 PSI PRESSURE INDICATOR 2 ½" Stainless C/W Stainless Needle Valve
PI-101/102/103/104	4	2 ½"	0 – 30 PSI PRESSURE INDICATOR 2 ½" Stainless C/W Stainless Needle Valve
PSHH-100	1	½"	CCS 6900 GZE12 PRESSURE SWITCH HIGH SET POINT 20 PSI
PSLL-100	1	½"	CCS 6900GZE12 PRESSURE SWITCH LOW SET POINT 5 PSI
SSV-100A/100B	2	1"	ASCO CSA 6.5 C/I GAS SOLENOID VALVE
SSV-101	1	¼"	ASCO ¼" CSA 6.5 C/I GAS SOLENOID VALVE
TCV-100	1	1"	KIMRAY 1350 C/W ¼" TRIM AND MINIMUM FIRE STOP
TE-100	1	-	WIKA 1000 SERIES DUAL EL.THERMO COUPLE (K) CL1D2
ZSC-100	1	-	TOPWORX PROXIMITY SWITCH MODEL LPS-DZ1NA2 CLASS I,II,III DIV 1

A	ISSUED FOR CONSTRUCTION	2013/01/28	SNA



Prepared By: SNA

Date: 2013/01/28

QUESTOR TECHNOLOGY INCORPORATED				
Client: Equinox Engineering - CNRL				
Location: Umbach Compressor Station				
Q20 Incinerator P&ID				
Job No.:	20121207-146	Dwg:	12146-D-P-201	Scale: NTS
Sheet:	1	Rev.:	0	