



**FIRE DETECTION**  
 NE 1300 AT 1300  
 NW 1300 AT 1300

**GAS DETECTION**  
 NE 1310 AT 1310 40% LEL  
 NW 1310 AT 1310 20% LEL

**V-130**  
**SALES GAS SEPARATOR**  
 VENDOR: PEERLESS  
 TYPE: WANE TYPE LINE SEPARATOR  
 SIZE: 510mm x 1459mm  
 CAP: 200 MMSCFD  
 OP/DT: 14569 kPa @ 66°C (211.3 PSIG @ 150°F)

**H-132**  
**CATALYTIC BLDG. HEATER**

**BF-133**  
**BUILDING FAN**

© TARTAN ENGINEERING LTD 2001

NOTES:  
 1.) 300 AND ON OUTLET FLANGE.  
 \* SUPPLY WITH HEATER

REV	REVISION	DATE	DRWN BY	CHKD BY	CVL APP	PRCD APP	MECH APP	ELCD APP	INST APP	SPSI APP	PRD END	QA	OWNER CHGD	OWNER APP
2	AS-BUILT (PROJ. #264502)	02.04.10	JG											
1	ISSUED FOR CONSTRUCTION (PROJ. #264502)	01.11.10	ML											
0	DESIGN REVIEW (PROJ. #264502)	01.09.10	JG											
C	PRELIMINARY DESIGN AND CLIENT REVIEW (PROJ. #264502)	01.09.10	ML											
B	ISSUED FOR O&G APPLICATION (PROJ. #264502)	01.08.10	ML											
A	CONCEPTUAL	01.08.10	ML											

PERMIT

ENGINEER



**AEC Oil & Gas**  
 LADYFERN CENTRAL DEHYDRATION FACILITY  
 b-47-H/94-H-1  
 SALES GAS SEPARATOR P&ID

SCALE NTS	PROJECT No 264502	DWG No A1-2645-B-105D	REV 2
--------------	----------------------	--------------------------	----------